

C-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2022/ 25

Dated: - 27/01/2022

To

The Managing Director,
Parag Bharati Model School,
81-84, Veena Enclave, Nangloi,
New Delhi- 110041.

Sub.: - Regarding issuance of Fire Safety Certificate in r/o Parag Bharati Model School located at 81-84, Veena Enclave, Nangloi, New Delhi- 110041.

Sir,

Please refer to your letter No. PBMS/2021 dated 12.10.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in your presence on 07/01/2022 to check the fire safety arrangements provided in the building.

During the inspection, it was also observed that the school building is comprised of ground plus two upper floors served by two staircases having width 1.50 mts each. Fire safety arrangement such as fire extinguisher, hose reel etc found provided in the school building. However, shortcomings were observed: -

1. Capacity of the terrace pump is less than required 450 LPM.
2. Width of main gate is less than 4.5 mts.
3. One hose reel is provided but not functional. One additional hose reel is required to meet the requirement.
4. Overhead tank capacity 1000 lts is provided against required capacity of 10000 lts.
5. Exit signages are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully


(Atul Garg)

Director
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

-for information please.