

C-13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/ 28

Dated: 27/01/2022

To

The Principal,  
S.D.M.C Primary School,  
Sheikh Sarai Phase-II,  
New Delhi 110017

Sub: Reg. renewal of Fire Safety Certificate in r/o S.D.M.C Primary School, Sheikh Sarai Phase-II,  
South Zone New Delhi 110017

Sir,

This is in reference with your Gmail Dated 02/01/2022 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 10.01.2022 in presence of Mr. Pratap Chandra (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. The First Aid hose reels provided but not functional and nozzles are missing.
2. The terrace level fire fighting pumps capacity 450 LPM provided but not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Director of Education, South MCD, Civic Center Minto road, New Delhi 110002