

250

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/School/WZ/2021/30

Dated: 27/01/2022

To.

The Principal,  
Bal Bharati Public School,  
Pawana Road, Pitampura,  
Delhi-110034.

**Sub. :-Renewal of Fire Safety Certificate in r/o Bal Bharati Public School Located at Pawana Raod, Pitampura, Delhi-110034.**

Sir,


Please refer to your email dated 15.11.2021 on the subject cited above. In this connection it is to inform you that the said School building has been inspected by the officer concerned of this department on 02.12.2021 in presence of Sh. Pranab Bhattacharya (Caretaker) to see compliance of the shortcomings communicated vide this department letter no. F6/DFS/MS/School/WZ/2021/606 dated 11.11.2021.

During the course of inspection it has been observed that the Management has rectified some of the shortcomings the status is under:-

S. no.	Shortcomings	Status
1.	Fire Check Door is removed from the lift lobby	Not yet Provided
2.	Fire Pumps not found functional due to maintenance work in progress	Rectified

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.