

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

237

No. F6/DFS/MS/School/MN/2021/34

Dated: 27/01/2022

To,

The Principal,
Sarvodaya kanya Vidyalaya
School No. 01, Chand Nagar
New Delhi.

Sub: - Regarding Issuance of Fire Safety Certificate in respect of M/ Sarvodaya kanya Vidyalaya, School No. 01, Chand Nagar, New Delhi. (School ID-1514011).

Sir,


Please refer to your Email dated: - 12/12/2021 on the subject cited above. In this connection it is to inform you that the premises was inspected by officer concerned of this department on 14/12/2021 in the presence of Sh. Ramjas (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the premises was comprised of + Ground + 01 Upper floor & Ground + Two upper floor (Two Block). Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, etc provided. However the following shortcomings were observed.

1. First Aid Hose reel are provided but not functional.
2. Terrace Fire Pump of 450 lpm is provided but not on auto mode.
3. Exit signages are not provided.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Directorate of Education old Secretariat, Delhi-110054.

ok
27/01/2022