

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2022/47

Dated:- 03/09/2022

To

The Principal,
Amity International School,
Mayur Vihar, Phase-1, Delhi - 110091.

Sub: Regarding Renewal of FSC in r/o Amity International School located at Mayur Vihar Phase-1, Delhi-91.

Sir,

This has reference to your letter no. AIS/MV/APP/FC/2022 dated 18/01/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 25/01/2022 in the presence of Mr. S Pandit (Admin Officer) and the following shortcomings were observed :-

1. 6 meter access encroached from one side.
2. Exhaust fan not provided in basement.
3. Hose reel & hydrant to be extended in basement.
4. MOEFA provided but not functional and to be extended in basement.
5. Sprinkler to be extended in left out areas and basement.
6. Temporary structure constructed at 4th floor.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

The Director (Education),
D-Block, Anand Vihar, Delhi - 91.