

c-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No. F6/DFS/MS/EH/WZ/2022/ 38

Dated: 31 / 01 / 2022

To,  
The Joint Commissioner of Police,  
Police Station Defence Colony,  
First Floor, New Delhi.

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Band Baaja Baaraat Located at Plot No.A-6, UGF, Vishal Enclave Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your online application no. 2021121328531 dated -14/12/2021 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 14/01/2022 in the presence of Mr. Tushar Gulati (Owner) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Upper Ground Floor in a Building comprised of Basement + Stilt + Upper Ground + 03 Upper floors + 02 rooms at terrace. Fire safety arrangements such as Fire Extinguishers, Smoke Management system, etc provided. However the following shortcomings were observed.

1. First-Aid Hose Reels are provided but not functional.
2. MOEFA is not provided.
3. Internal Hydrant is provided but not functional.
4. Main Fire Pump of capacity 450 lpm is not provided.
5. Over head water storage capacity of 20000 ltrs is not provided.


In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Owner/Occupier, M/s Band Baaja Baaraat Located at Plot no A-6, UGF, Vishal Enclave Rajouri Garden, New Delhi-110027.
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.

  
27/01/2022