



2-11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

F.6/DFS/MS/EH/2022/SZ/157

Dated: 01/02/2022

To

The Dy. Health Officer,
South Zone, SDMC, Green Park,
Aurobindo Marg, New Delhi

Sub: Issue of Fire Safety Certificate in r/o M/s BERCOS (A Unit of BERCOS MELODY HOUSE) at Shop No 17 & 18. Food Court, DLF Prime Tower, Okhla Phase-1, Delhi-110020.

Sir,

This is in reference to with MHA Portal ID 2021121328482 dated 15/12/2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Atul Kakkar (Manager) on dated 07-01-2022 & observed that the building is comprised of 02 tier Basement, Ground + 08 upper floor and restaurant running at Ground floor of the building. During the course of inspection, the following shortcoming observed were noticed:-

1. There is one door having width of 2.0 mtr against the required two doors having width of 02 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR / DFS

Copy to: -

1. M/s BERCOS (A Unit of BERCOS MELODY HOUSE) at Shop No 17 & 18. Food Court, DLF Prime Tower, Okhla Phase-1, Delhi- 110020