

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE <u>CONNAUGHT PLACE: NEW DELHI–110001</u>

## No. F.6/DFS/MS/EH/2022/SZ/148

Dated: 0/ /02/2022

To

Mr. Puneet Jain, M s Dominos Pizza (Jubilant Foodworks Ltd). Shop No. 32–33. Ground Floor, Grandlay Cinema Complex. New Friends Colony. New Delhi–110025

Sub: Inspection Report in respect of M/s Dominos Pizza (Jubilant Foodworks Limited) situated at Shop No. 32–33, Ground Floor, Grandlay Cinema Complex, New Friends Colony, New Delhi–110025

Sir.

This is with reference to your online application No. 2022010400202 dated 08/01/2022. In this connection, it is to inform you that the said premises was visited by the officer concerned of this department on 18/01/2022 in the presence of Mr. Mukesh Kumar (Asst. Manager) of the restaurant to verify the compliance of fire safety measures required under the rules. During the course of inspection, the shortcoming observed is as below.

1. Width of one of the exit/door found less than the required width of 1.5m.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premise in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,

Delhi Fire Service

Copy to: -

 The Dy. Health Officer, South MCD, Public Health Department, Central Zone, Jal Vihar, Lajpat Nagar, New Delhi –110024