

13  
C-14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F6 /DFS/MS/EH/NDZ/2022 | 36

Dated: 31/1/22

To

The Joint Commissioner of Police,  
Office of Joint commissioner of Police: Licensing,  
1st Floor, P S Defence Colony, New Delhi.

**Sub:** - Regarding grant of Fire Safety Certificate in r/o M/s Jubilant Foodworks Ltd. (Domino's Pizza) located at E-23, GF Netaji Subhash Road, Darya Ganj, Delhi.

Sir,

With reference to the online application I.D. no. 2022010700397 dated 07.01.2022 on the subject cited above, it is informed that the said restaurant was inspected by Assistant Divisional Officer (SPM) from this department on 21.01.2022 in the presence of Mr. Amit Jain, Area Manager and it was observed that the restaurant is running only on the ground floor of a building which is comprised of ground + 02 upper floors at the address mentioned in the subject . During the inspection the following shortcomings were observed: -

1. Main & Alternate exit width was not meeting the requirement. Both the exits should have minimum width of 1.5 meters each.
2. First aid hose reel found not provide
3. Manually operated electric fire alarm (MOEFA) system found inadequate & non functional.
4. Down comer system found not provided.
5. Fire pump having capacity 450 LPM & 40 mtrs head found not provided.
6. Overhead tank capacity 20,000 liters for firefighting found not provided.
7. Exit signages found not provided.
8. Oil filled stabilizer must be segregated from the common area/ exit route and shall be adequately protected.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Anil Garg)

Director

Tel: 011-23414000

alc DL  
28/1/22

**Copy to:-**

The Licensee,  
M/s Jubilant Foodworks Ltd. (Domino's Pizza) located at E-23, GF Netaji Subhash Road, Darya Ganj, Delhi.