

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/2022/SZ/EH/147

Dated: 01 / 02 / 2022

To

Mr. Puneet Jain,
M/s Jubilant Foodworks Limited (Dominos Pizza),
G-24, First Floor, South Extension Part-I,
New Delhi-110049

Sub: Inspection report in respect of M/s Jubilant Foodworks Limited (Dominos Pizza) situated at G-24, First Floor, South Extension Part-I, New Delhi-110049

Sir,

This is with reference to the online application No. 2022010400197 dated 07/01/2022. In this connection, it is to inform you that the said premises have been inspected by the officer concerned of this department on 19/01/2022 in the presence of Ms. Seema Maurya (Shift Manager) from fire safety point of view. The following shortcomings have been observed: -

1. Single staircase of 1.10m width is provided against required two staircases having width of 1.5m each.
2. Single exit/door of 1.07m width is provided against required two exits/doors having clear width of 1.5m each.
3. The required first aid hose-reel is not provided.
4. The required internal hydrant is not provided.
5. The overhead water storage tank of capacity approx. 5,000 Ltrs is provided against requirement of 20,000 Ltrs.
6. Exit signage not provided.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premise in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, South MCD, Public Health department, Green Park, Aurobindo Marg, New Delhi-110016