

C-17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2022/SZ/44

Dated: 01/02/2022

To,


The Manager,
M/s Jubilant Foodworks Ltd (Dominos Pizza),
C-24/7, Plot No.-7, Roshanpura, Najafgarh, New Delhi,

Sub:-Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Jubilant Food works Ltd (Dominos Pizza), C-24/7, Plot No.-7, Roshanpura, Najafgarh, New Delhi.

Sir,

This has reference to your application ID no. 2022011200660 dated 12/01/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 18/01/2022 in the presence of Sh. Sonu Sahu (Manager) to verify the compliance of shortcoming already communicated by this department vide letter no. F6/DFS/MS/EH/2019/SZ/6809 dated 14/11/2019 and observed that shortcomings are still not rectified. It is advised that occupancy should not be allowed till fire safety arrangements are provided in the restaurant.

Yours faithfully


(Sunil Chawdhary)

Dy.Chief Fire Officer



Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.
(With a request to take further action as eating house does not have fire NOC)

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2019/SZ/ 6809

Dated: 14/11/19

To,

The Joint Commissioner of Police,
Licensing Unit, Office of the Joint Commissioner of Police,
1st Floor, Police Station, Defence Colony, New Delhi

Sub: - Regarding renewal of registration certificate of eating house in the name and style of M/s Jubilant Foodworks Ltd. (Domino's Pizza), C-24/7, Plot No.-7, Roshanpura, Najafgarh, New Delhi.

Sir,

This has reference to your letter no. 32670/Jt./CP/Lic./EH(DA-VI) dated New Delhi the 27.08.2019 on the subject cited above. In this regard, it is to inform you that the inspection of above said premises has been carried out by officers concerned of this department on 09.10.2019 to see the compliance of the requisite fire safety measures. Sh. Suraj (Manager) was present at the time of inspection.

During the course of inspection it was observed that the building is comprised of ground floor plus three upper floors but restaurant is running at Ground floor & first floor only (second & third floor locked). The upper floors are served by two staircases having width 145 & 95 cms. The building is approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The following shortcomings were observed:

1. The upper floors are served by two staircases having width 145 & 95 cms against required two staircases having width 200 cms & 150 cms each.
2. Door width is 220 & 96 cms at GF & 140 & 95 cms at FF against required 200 & 150 cms at each floor.
3. Ventilation system not provided.
4. MOEFA with talk back system not provided.
5. PA system not provided.
6. Internal hydrant system not provided.
7. Hose reel system not provided.
8. Terrace fire pump of 450 LPM capacity not provided.
9. Overhead water storage tank of 20,000 ltrs capacity not provided.
10. Illuminated Exit signs not provided.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy:-

Sh. Yunus Khan,
M/s Jubilant Foodworks Ltd. (Domino's Pizza), C-24/7, Plot No.-7, Roshanpura,
Najafgarh, New Delhi