



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/39

Dated: 01/02/2022

To,

The Principal,
Rukmini Devi Public School,
B-5, Sector-4, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85.

Sir,

This is in reference to your letter No. RDPS/2021-22/831 dated 27.11.2021 received through outdoor diary no. 9813 dated 30.11.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **17.01.2022**, in presence of **Sh. Parveen Gupta (Chairman)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Two pumps of 450LPM & 180lpm is provided but not functional at the time of inspection.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
[s/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully

(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

o/c
Dy