

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/EH/WZ/2022/ 39

Dated 31/1/22

To,

The Joint Commissioner of Police,
Licensing unit, 1st Floor,
Police Station Defense Colony, New Delhi.

Subject: Inspection report for issuance of Fire Safety Certificate in r/o M/s. Suravie (a unit of TNA Entrepreneur), located at Shop No.- SH-2F-06, Second Floor, M/s. Pacific Development Corporation Ltd. (Pacific Mall), Netaji Subhash Place Metro Station, New Delhi.

Sir,

With reference to the online application received through MHA portal vide ID-2021120427850 on the subject cited above. In this connection it is to inform you that the above said premise was inspected by the officer concerned of this department on 03.01.2022 in presence of Sh. Naveet Gupta (owner), to check the required fire safety arrangements as per laws in the building.

During the course of inspection, it was observed that the restaurant is running at second floor in a building comprised of 02 tier basement, lower ground, ground plus four upper floors. Fire safety arrangements such as fire extinguishers, first aid hose reel, internal hydrant system, U.G.Tank, overhead water storage tank, fire pump etc. found provided. However, following shortcomings were observed: -

1. Width of alternate exit is less than required width 1.5 mts.
2. Exit signages are not provided.
3. Seating arrangement provided in the mezzanine of second floor is not sanctioned as per building plan available in the file of Pacific Mall, NSP Metro Station.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority /statutory authority is requested that premises should not be allowed to run till it provide all necessary fire safety arrangements.

Yours faithfully


(Anil Garg)
Director

Copy to:

1. The Owner/occupier, M/s. Suravie (a unit of TNA Entrepreneur), at Shop No.- SH-2F-06, Second Floor, M/s. Pacific Mall, Netaji Subhash Place Metro Station, New Delhi.
2. The Deputy Health Officer, Keshav puram Zone, North DMC, A-1, Keshav puram, New Delhi.