

Frequent hand sanitization-wearing of face mask-keep physical distance to prevent from Covid-19

C-13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/BP/2022/ 13

Dated: 01.01.2022

To,


Sh. Vivek Nagpal,
M/s Symphony Grand Banquet,
Located at Plot No. 7, Pitampura,
Near apeejay public School, Delhi-110034.

Sub: - Issue for the Fire Safety Certificate/NOC, in respect of M/s. Symphony Grand Banquet,
Located at Plot No. 7, Pitampura, Near apeejay public school, Delhi-110034.

Sir,

This has reference to your application No. 2021112627289 dated 01.12.2021 received from on the subject cited above. In this connection it is to inform you that the uploaded floor plans are in pdf format on MHA portal and the plans are not in scale therefore, it cannot be scrutinized from fire and safety point of view. As this is new case, therefore you are advised to forward complete set of building plans including section/elevation/lay out plan of current occupancy in the scales as mentioned in UBBL-2016 duly marked with fire and life safety systems as per NBC part-IV to assess the fire and life safety requirement for issuance of fire safety guidelines/ directives.

Yours faithfully



(VIRENDRA SINGH)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Health Officer,
South Delhi Municipal Corporation,
West Zone, Rajouri Garden, New Delhi.
2. The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi.


25/1/2022