GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2022/ 4 0

Dated: 31/1/22

To

The Joint Commissioner of Police (Lic.), 1st Floor, Police Station Defence Colony, New Delhi.

Sub.:- Inspection report for issue of Fire Safety Certificate in r/o The Coffee Bean and Tea Leaf, a unit of M/s Pan India Food Solutions Solution Pvt Ltd, located at Unit R-01, GF, Epicuria Galley, Rajouri Garden, New Delhi- 110027.

Sir,

Please refer to the online application No. 2021111026090 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department, in presence of Sh. Ashok Jadav (owner/occupier) on 03.01.2022 to check the status of fire safety arrangements provided in the premises.

During inspection, it has been observed that the said restaurant is running on ground floor of a building comprised of basement, ground plus three upper floors. Fire safety arrangement such as U.G. Water storage tank, overhead water storage tank, fire pumps, fire extinguishers, Internal Hydrant, first aid hose reel hose, MOEFA etc. found provided. However, following shortcomings were observed: -

- 1. Alternate exit is less than the required width of 1.5 mts.
- 2. Exit signages are not provided.

In view of the above shortcomings, the application for grant of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite Fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority /statutory authority may take suitable necessary action as deemed fit.

Copy to: -

- 1. The Deputy Health Officer, South Delhi Municipal Corporation, West Zone, Rajouri Garden, New Delhi.
- 2. Sh. Ashok Jadav, Owner/occupier, The Coffee Bean and Tea Leaf restaurant, a unit of M/s Pan India Food Solutions Solution Pvt Ltd., Unit R-01, GF, Epicuria Galley, Rajouri Garden, New Delhi- 110027.