

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

No.F6/DFS/MS/MN/GH/2021/93

Dated: 01/02/2022

C48

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Subject: Regarding Renewal of NOC from fire safety point of view in respect of M/s The Met Restaurant (A unit of Westt Face Services) located at 17-A, North Avenue, Punjabi Bagh, New Delhi- 110026.

Sir,

Please refer to your online application no. 2021111426384 dated 14/11/2021 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officers of this department on 04/01/2022 to check the fire safety arrangements.

During inspection, It was observed that the building is comprised of Basement, Ground plus 03 Upper Floors. Restaurant is running at Ground Floor. Fire safety arrangements such as Smoke Management System, Fire Extinguishers, First-Aid Hose Reels, MOEFA, Internal Hydrant etc. found provided. However, following shortcomings were observed:-

1. Door size of 1.5 mtr & 2nd door is less than 1.5 mtr are provided against requirement of 1.5 mtr each.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. M/s The Rajesh Gulla, The Met Restaurant (A Unit of Westt Face Services) located at 17- A, North Avenue, Punjabi Bagh, New Delhi – 110026.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.