

C-48

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/42

Dated: 01/02/2022

To,

The Principal,  
Vidya Jain Public School,  
Sector-6, Rohini,  
Delhi-110085,

**Sub:** Issue of FSC in r/o Vidya Jain Public School, Sector-6, Rohini, Delhi-110085.

Sir,


This is in reference to your letter No.4840 dated 22.10.2021 received through outdoor diary no. 3873 dated 02.11.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 17.01.2022, in presence of **Sh. Neeraj Kumar (Care Taker)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Two pumps of 450 LPM is provided but not functional at the time of inspection.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule)  
[s/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250

OK  
04