

C-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/NDZ/ 55

Dated: 09/02/2022

To,

The Principal,  
E. D. M. C. Primary School,  
Kailash Nagar, Gali No. 12,  
Delhi-110031

**Subject:- Regarding issuance of Fire Safety Certificate.**


Sir,

With reference to your letter no. E.E. (Elect.)-II/Shah(S)/2021-2022/D-570 dated 27/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Manisha Kumari, Principal & Sh. Kuldeep Kumar Singh, J.E (Electric), Shahdara South Zone on dated 29/11/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations was made:-

1. Two staircase of width 1.5 meter each is required to be provided in the building.
2. Complete set of building plans are not submitted.
3. Approach road width is less than 6 meter.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further necessary action.

Yours faithfully,

  
K. D. Garg  
Director  
JD..

Copy to:-

The Director of Education, EDMC  
Udyog Sadan, Plot No. 419, FIE,  
Patparganj, Delhi -92