

c/19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/ 51

Dated: 04/02/2022

To,

The Principal
Oxford Modern Public School,
1/4551-52, Ram Nagar Extn,
Shahdara, Delhi-110032.

Sub:- Regarding Issuance of Fire Safety Certificate in r/o Oxford Modern Public School
Located at 1/4551-52, Ram Nagar Extn, Shahdara, Delhi-110032.

Sir,

This is in reference to your Letter no. OMPS/01/2022 dated 15/01/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Kuldeep Tyagi (Manager) of the School. During the course of inspection, the following points / shortcomings were noticed in the building comprised of ground plus three upper floors.

1. Fire Extinguisher's provided but not functional at the time of Inspection
2. First-Aid Hose reel provided but not functional at the time of Inspection.
3. A fire pump having 450 LPM output at 40 meters head is provided but not functional.
4. Over head tank 8,000 liter provided in place of 10,000 liter as required.
5. Exit Signage's are not provided.
6. Standby power supply are not provided.
7. Santioned plan/ built plan on the scale of 1:100 are not Submitted

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

The Dy. Director of Education, EDMC
B-Block, Yamuna Vihar,