

C-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/63

Dated: 11/02/2022

To,

The Principal,  
Angels Public Senior Secondary School,  
Sahdev Gali, Vishwas Nagar, Shahdara,  
Delhi-110032

Subject:- Regarding Fire Certificate.

Sir,

With reference to email ID [angelspublicschool1@gmail.com](mailto:angelspublicschool1@gmail.com) dated 18/12/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Savita Raha, Incharge on dated 02/02/2022. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-


1. An overhead water tank having 3,000 liters capacity is provided against the required capacity of 5,000 liters.
2. Firefighting system (fire pump & hose reel) which have been provided in the building, was not functional.
3. Exit signs are required to be provided in the school building at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer



Copy to:-

The Director of Education,  
GNCT of Delhi, Old Secretariat,  
Delhi-54