

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/ 194

Dated:-15.02.2022

To

The Manager  
M/S Domino's Pizza (M/S Jubilant Food Works Limited Domino's Pizza)  
8/8, 2159XV, Ground & First Floor,  
D.B.G, Pahar Ganj, New Delhi.

**Sub: Regarding issuance of FSC in r/o M /S Domino's Pizza ( M/S Jubilant Food Works Limited Domino's Pizza) located at 8/8, 2159XV, Ground & First Floor D.B.G, Pahar Ganj, New Delhi ID NO. 2022011200658 dated 12.01.22**

Sir,

This has reference to online ID No. **202201120658 dated 12.01.22** on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 09/02/2022 in the presence of Sh. Kuldeep and following shortcomings were observed:-

1. 02 Staircases of 1.5 meter each are not provided.
2. First aid hose reel and hydrant systems are not provided.
3. Terrace pump of 450 LPM is not provided.
4. Overhead fire water tank of 20,000 liter capacity is not provided.
5. The building plan as uploaded is not signed by owner /occupier himself.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.