GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE **NEW DELHI**

No. F6/DFS/MS/WZ/EH/2023/ | 84

Dated: 1/02/2029

To.

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Sub: - Inspection report in r/o Dutyfree (A unit of Night House Café Pvt. Ltd)C-10, Upper Ground Floor, vishal Enclave, Rajouri garden, New Delhi-110027

Sir,

Please refer to your online application no.:- 2021113027536 dated 30/11/2021 on the subject cited above. In this connection it is to inform you that the premises was inspected by officers concerned of this department on 28/01/2022 in the presence of Sh. Bala Dutt (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the restaurant is running at Upper ground floor in a building comprised of Basement + Stilt+ Ground + 02 Upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant & Terrace Pump etc provided. However the following shortcomings were observed.

- 1. Staircases size 1.5 mtr & 1.20 mtr are provided against requirement of 1.5 mtr each.
- 2. Door size 1X1.20cms, 1X 1.05 cms against requirement of 1.5 mts each.
- 3. Smoke management system is not provided.
- 4. First Aid hose reel provided but not functional.
- 5. Internal Hydrant is provided but not functional.
- 6. Terrace Fire Pump of 450 lpm is provided but not functional.
- 7. Over head water storage tank capacity of 5,000 ltrs is provided against requirement of 20,000 ltrs.
- 8. Exit signages are not provided.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

Delhi Fire Service

Copy to: -

Online application ID no.:- 2021113027536 dated 30/11/2021

2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id: - (dhowest zone@gmail.com).