

C-71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/School/68

Dated: 14/02/2022

To,
The Principal, <adminmanager@gdgoenkadwarka.com>
G.D Goenka Public School,
Sector-10, Dwarka,
New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate in r/o G.D Goenka Public School Located at Sector-10, Dwarka, New Delhi – 110075.

Sir,
Please refer to your Email Dated 31/12/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 01/02/2022

During the course of inspection following shortcomings are observed.

1. Six meter wide internal road found encroached at corner.
2. Fire Check Doors found removed at some places.
3. Pressurization system found removed in staircases.
4. Smoke exhaust system found nonfunctional in basement & upper floors.
5. Smoke detectors are found removed at some places.
6. P A system found nonfunctional.
7. Manual Operated Emergency Fire Alarm System found nonfunctional
8. Lift Lobby found removed.
9. Pressurization System provided for lift shaft found nonfunctional in auto mode.
10. Hose reel hoses & Hydrants found non functional.
11. Terrace Pump found no nonfunctional.
12. School activities are noticed in basement.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to:- Directorate of Education Old Secretariat Delhi – 110054