

c/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/ 85

Dated: 11/02/2022

To.

The Principal,
Lovely Public Middle School,
5, Old Geeta Colony,
Delhi-110031

Subject:- Renewal of Fire Safety Certificate.

Sir.

With reference to email ID lpsjupiter@yahoo.co.in dated 12/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Sunita Dhingra (A.M.) on dated 14/01/2022. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

1. An overhead water tank having 2,000 liters capacity is provided against the required capacity of 10,000 liters.
2. Firefighting systems (fire pump & hose reel) which have been provided in the building, was not functional.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

O/c D.F.S.

Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-110054