

C12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/ 58

Dated:- 10/02/2022

To,

The Principal,
Nutan Vidya Mandir School,
A.G.C.R. Enclave,
Delhi-110092

Subject:- Issue of Fire Safety Certificate.

Sir,

With reference to your email ID nvm.agcr@gmail.com dated 24/12/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Rashmi Pillai, Principal on dated 10/01/2022. The School building comprises of basement, ground plus one upper floor. During the course of inspection following observations were made:-

1. An overhead water tank having 5,000 liters is required to be provided exclusively for fire fighting.
2. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided at terrace level.
3. Automatic Sprinkler System is required to be provided in the basement.
4. Exit signages are required to be provided at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

(Atul Gang)
Director

Copy for information and necessary action . if any :-

1. The Director of Education,
D- Block, Anand Vihar,
Delhi.

Note:- Fire Safety Certificate No. F-6/065/05/School/512 dated 10/11/2018 furnished by school has not been issued by this department.