

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001 C-29

No.F6/DFS/MS/School/NDZ/2022/ 67

Dated:- 14 /02/2022

To

The Principal,
Rajkiya Sarvodaya Bal/Kanya Vidyalaya,
Kalyanvas, Delhi – 110092.

Sub: Regarding Renewal of FSC in r/o Rajkiya Sarvodaya Bal/Kanya Vidyalaya located at Kalyanvas, Delhi – 110092.

Sir,

This has reference to your letter no. RSKV/KV/2021/513 dated 24/01/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 09/02/2022 in the presence of Mrs. Meenakshi Goyal (H.O.S.) and the following shortcomings were observed :-

A-Block – Gr. + 02 upper floors, B & C – Block Gr. + 01 upper floor.

1. Hose reel not functional.
2. Fire pump not functional.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education),
D-Block, Anand Vihar, Delhi - 91.

