

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2022/ 60

Dated:- 11/02/2022

To

H.O.S,
Sarvodaya Co-Ed. Sec. School,
I.P. Extn., Delhi - 110092.

Kind Attention:- Sh. Anil Kumar Gautam

Sub: Regarding grant of FSC in r/o Sarvodaya Co-Ed. Sec. School located at I.P. Extn. Delhi-92.

Sir,

This has reference to your letter no. S-Co-ed/SSS/IPE/2021-22 dated 28/10/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 23/12/2021 & 04/02/2022 in the presence of Mr. Anil Kumar Gautam (Estate Officer) that building comprised of Ground + 03 upper floors, Ground floor and multipurpose hall 1st floor converted in to offices of **Delhi Board of School Education** and 2nd floor & 3rd floor as school and the following shortcomings were observed :-

1. MCP provided but not functional.
2. Fire pump provided but not functional.
3. At ground floor & 1st floor complete wooden paneling in corridors and offices all wooden material to be treated with fire retardant paint.
4. In multipurpose hall, hose reel hose, hydrant and exit signage to be extended.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Director (Education),
D-Block, Anand Vihar, Delhi - 91.

gk
mw