

C/35



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F.6/DFS/MS/BNQT/2022/NDZ/ 20

Dated: 11/02/2022

To:

Sh. Mukesh Aggarwal,
Shri R. G. Enterprises Aqua Tree,
B-19, Second Floor,
Jhilmil Industrial Area, Shahdara,
Delhi-110092

Subject: Renewal of Fire Safety Certificate.

Sir,

With reference to your email ID hotelsraman@gmail.com dated 10/01/2022 on the subject cited above, it is informed that officer concerned of this department visited the Shri R. G. Enterprises Aqua Tree on dated 14/01/2022 and observed that the shortcomings issued vide letter No. F.6/DFS/MS/BNQT/2021/NDZ/2741 dated 24/12/2021 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. Therefore, you are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully,


21/2/22

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Dy. Health Officer,
EDMC, Public Health Department,
Shahdara (South) Zone,
Karkardooma, Shahdara, Delhi-110032

C/31

130

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/BNQT/2021/NDZ/ 2741

Dated: 24/12/21

To,

Sh. Mukesh Aggarwal,
Shri R. G. Enterprises Aqua Tree,
B-19, Second Floor,
Jhilmil Industrial Area, Shahdara,
Delhi-110092

Subject: Renewal of Fire Safety Certificate.

Sir,

With reference to your online letter No. 2021101824473 dated 25/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the Shri R. G. Enterprises Aqua Tree from fire safety point of view in presence of Sh. Sourabh Jain on dated 22/11/2021. During the course of inspection following observations were made:-

1. Diesel Fire pump found removed.
2. Clear width of 2 meter & 1.50 meter respectively are required to be provided from ground floor to Terrace.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Dy. Health Officer,
EDMC, Public Health Department,
Shahdara (South) Zone,
Karkardooma, Shahdara, Delhi-110032

