

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/ 64

Dated: 11/02/2022

To,

The Manager,
St. Vivekanand Modern School,
6/50, Street No. 4, Vishwas Nagar,
Shahdara, Delhi-110032

Subject:- Renewal of Fire Safety Certificate.

Sir,

With reference to your email ID svmsvng@gmail.com dated 26/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Shefli, Incharge on dated 02/02/2022. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

1. An overhead water tank having 7,000 liters capacity is provided against the required capacity of 10,000 liters.
2. Firefighting system which has been provided in the school building, was not functional.
3. Exit signages are required to be provided at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Director of Education, EDMC,
Plot No. 419, Udyog Sadan,
FIE, Patparganj, Delhi-110092