

228
C24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/185

Dated: 11/02/2022

To

Mr. Manish Ranjan,
M/s Starbucks Coffee – A Tata Alliance,
D-27, Ground Floor, Defence Colony,
New Delhi-110049


Sub: Regarding issuance of Fire Safety Certificate in r/o of M/s Starbucks Coffee – A Tata Alliance, D-27, Ground Floor, Defence Colony, New Delhi-110049

Sir,

This has reference to online application No. 202201300702 dated 13/01/2022, on the subject cited above. In this connection, it is to inform that the said premise was visited by the officer concerned of this department on dated 28/01/2022 in presence of Mr. Vaibhav Rai Bhatia (Manager) of the restaurant to verify the compliance of shortcomings communicated by this department vide letter No. F6/DFS/MS/EH/2020/918 dated 18/12/2020 (copy enclosed) and observed that the shortcomings have not yet been complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premise in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, South Delhi Municipal Corporation, Public Health Department, Central Zone, Jal Vihar, Lajpat Nagar, New Delhi-110024

C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. f6/DFS/MS/EH/2020/918

Dated: 18/12/2020

To,

Additional Commissioner of Police,
Licensing Unit, 1st Floor, Police Station Defence Colony,
New Delhi.

Subject: Inspection report of M/s Starbucks Coffee – A Tata Alliance, D-27, Ground Floor, Defence Colony, New Delhi, from Fire Safety and means of escape point of view.

Sir,

Please refer to your letter No. MHA ID-2019120300758 dated 11/12/2019 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 20/11/2020 in presence of Mr. Vaibhav (Manager).

During the course of inspection, it was observed that the building premises is comprised of Basement (Other Party), **Ground Floor (Proposed Restaurant)**, 1st Floor, 2nd Floor & 3rd Floor (Spa). Fire Safety Arrangement such as Fire Extinguishers, Hose Reel Hose, Internal Hydrant & Over Head Tank of 5,000 ltr and two Fire Pumps of 450 liter / Minute capacity were found provided.

However following shortcomings were observed during the time of inspection:-

1. Two Doors of width 2.00 mtr & 1.30 mtr are provided against requirement of 2.00 mtr & 1.50 mtr widths.
2. Over Head Tank of 5,000 ltr provided against requirement of 20,000 Ltr.

In view of above NOC/ FSC is rejected under sub rule (3) of Rule 35 of Delhi Fire Service Act 2007 & Rules 2010.

You are requested to rectify above mentioned shortcomings under intimation to this department for further necessary action please.

Yours faithfully,


(ATUL GARG)
DIRECTOR.

Copy to:-

1. The Dy. Health Officer, South Zone, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi.
2. Authorized Signatory, M/s Starbucks Coffee – A Tata Alliance, D-27, Ground Floor, Defence Colony, New Delhi -110049.