

C-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2022/SZ/ 186

Dated 11/02/2022

To,

Dy. Health Officer,  
SDMC Public Health Department,  
West Zone, Rajouri Garden, New Delhi-110027.

Sub:- Online application ID 2022010700439 in r/o M/s Jubilant Food works Ltd.( Domino Pizza),  
Upper Ground Floor, BF-4, Main Jail Road, Janakpuri, New Delhi-110058.

Sir,

This has reference to online application ID 2022010700439 dated 07/01/2022 on the subject cited above. In this regard it is to inform you that drawing submitted with online application and other details are not matching with the actual building profile.

Hence the application needs correction in respect of information of total nos. of floors, no. of specific floors in which establishment is situated & clear width of staircase & no's. and dimensions in meter.

Accordingly the applicant may be directed to furnish correct & complete information for further necessary action for issuance of Fire Safety Certificate.



(Sunil Chawdhary)  
**Dy. Chief Fire Officer**  
Delhi Fire Service

o/c

Copy to:-

The Manager,  
M/s Jubilant Food works Ltd.( Domino Pizza),  
Upper Ground floor, BF-4, Main Jail Road, Janakpuri, New Delhi-110058.