

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2022/NDZ/ 62

Dated: 11/02/2022

To,

The Manager,
Bharat National Public School,
Ram Vihar, Karkardooma,
Delhi-110092

Subject:- Application for Renewal of Fire Safety Certificate.

Sir,

With reference to your email ID bnpsramvihar@yahoo.com dated 17/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. Mahesh Ranga, Administrative Head on dated 16/12/2021. The school building comprises of ground plus four upper floors. Inspection was carried out in wake of No. F.6/DFS/MS/BP/2015/School/319 dated 10/12/2015. During the course of inspection following observations were made:-

1. An overhead water tank having 5,000 liters capacity is provided against the required capacity of 25,000 liters.
2. A fire pump with 450 LPM discharge at 40 meters head (4kgf/sq.cm.) is provided against the required pump with 900 LPM.
3. Internal road not provided.
4. Pressurization of lift shaft is required.
5. Fire control room should be established at entrance floor.
6. HT & LT panels shall be separate with the walls of 2 hours fire resistance rating.
7. Exit signages are required to be provided at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

(Atul Garg)
Director

gc Sh. ...

Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-110054