

n.l.m.
C80

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2022/SZ/ 151
To

Dated: 21.1.2022

The Joint Commissioner of Police, (Lic/Branch)
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Issuance of NOC in r/o M/s Amar Inn Guest House, at K-102, Jal Vihar Road, Lajpat Nagar-II, New Delhi 110024

Sir,

This is in reference with MHA Portal ID 2022010500280 dated 08/01/2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 09/02/2022 in the presence of Sh. Gurdev Singh (owner) of the Guest House. During the inspection, it was observed that the building comprised of Basement + Ground + 03 Upper Floor. The shortcomings observed are as below;

1. There were two staircases in the existing guest house building having width of 1.25m & 0.63 m. which were communicating from ground to upper floor. The second staircase having width of 0.63 mtr now has been removed.
2. Hose reel hose provided but not on working.
3. Terrace level Fire Pump capacity of 450 LPM provided but not in working.
4. Overhead tank capacity 1,000 ltrs provided against the requirement of 10,000 ltrs.
5. Exit signage found removed.
6. Standby power supply found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. M/s Amar Inn Guest House, at K-102, Jal Vihar Road, Lajpat Nagar-II, New Delhi 110024,