

2657



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2022/SZ/ 152
To

Dated: 21.1.02/2022

The Joint Commissioner of Police, (Lic/Branch)
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Issuance of NOC in r/o M/s Hotel Richa Place, at B-109, Lajpat Nagar-1, New Delhi 110024

Sir,

This is in reference with MHA Portal ID 2022010300074 dated 11/01/2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 09/02/2022 in the presence of Sh. Subhash Kumar (Manager) of the Guest House. During the inspection, it was observed that the building comprised of Basement + Ground + 04 Upper Floor. The shortcomings observed are as below;

1. Hose reel hose provided but not working.
2. MOEFA provided but not working.
3. Automatic sprinkler system provided in basement but not functional.
4. Terrace level Fire Pump capacity of 900 LPM provided but not in working.
5. Overhead tank capacity 2,000 ltrs provided against the requirement of 10,000 ltrs.
6. Exit signage found removed.
7. Standby power supply found removed.
8. As per the notification dated 27/05/2019 fire NOC will not be issued to guest houses, which have more than four floors (excluding basement & stilt floor).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

out

Copy to:-

1. M/s Hotel Richa Place, at B-109, Lajpat Nagar-1, New Delhi 110024

5