

C-70

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2022/94/153

Dated:-21.02.2022

To

The Manager,
M/S Marco Polo Guest House,
8593/01, A.K. Road,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Marco Polo Guest House at 8593/01, A.K. Road, Paharganj, New Delhi. ID no. 2022012501217 dated 27.01.22.

Sir,

This has reference to online ID No. **2022012501217 dated 27.01.22** on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 08/02/2022 in the presence of Sh. Sushil and following shortcomings were observed:-

1. MOEFA is not provided.
2. PA system is not provided.
3. Terrace pump provided of capacity 180 LPM against the requirements of 450 LPM
4. The building plan as uploaded on the portal not signed by the owner himself.
5. Further, Compliance of notification dt. 27.05.19 is to submitted by 31.03.2022.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


17/2/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.