

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

29

No.F6/DFS/MS/NDZ/2022/EH/199

Dated:- 21/02/2022

To

The Manager,
M/S Nazeer Hospitality Pvt. Ltd.,
M-42, Ground Floor,
Outer Circle, Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Nazeer Hospitality Pvt Ltd at M-42, ground & mezzanine floor, outer circle , Connaught place New Delhi ID NO.2021061113761 dated 11.06.21

Sir,

This has reference to online ID No. **2021061113761 dated 11.06.21** on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 14/02/2022 in the presence of Sh. Ajit and following shortcomings were observed:-

1. Alternate of exit of 1.5 meter width is not provided.
2. 02 Staircases of 1.5 meter width each are not provided.
3. First aid hose reel and hydrant systems are not provided.
4. Terrace pump of 450 LPM is not provided.
5. Overhead fire water tank of 20,000 liter capacity is not provided.
6. The building plan of the restaurant is not uploaded on the portal.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.