

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/SZ/School/2022/ 72

Dated: 21/02/2022

To

The Principal,
New Mother Saraswati School
G-657, Sangam Vihar,
New Delhi-110062

Sub: Regarding issuance of Fire Safety Certificate in r/o New Mother Saraswati School at G-657, Sangam Vihar, New Delhi-110062.


Sir,

This is in reference to with Gmail dated 31-01-2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Madan Mohan Sharma on 04-02-2022 & observed that the building is comprised of Ground + Two upper floor. During the course of inspection, the following shortcoming observed were noticed:-

1. First Aid Hose Reel hose provided but not functional.
2. Terrace level fire fighting pumps capacity 450 LPM provided but not working.
3. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054