



26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/SZ/EH/2022/ 197

Dated: 21 /02/2022

To

The Dy. Health Officer,
South Zone, SDMC, Green Park Zone,
Aurobindo Marg, New Delhi - 110016

Sub: Regarding Issuance of Fire Safety Certificate in r/o M/s Secular House Canteen (A Unit of Masala Bites Secular House Canteen situated at 9/1 Ground Floor, Qutab Institutional Area New Delhi-110067

Sir,

This is in reference to with MHA Portal ID 2022011400785 dated 14/01/2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 02-02-2022 in presence of Sh. Amit Kumar (Manager) & observed that the building is comprised of Ground floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. There are two doors having width of 1.20 mtr & 1.20 mtr against the required width of 1.50 mtr each.
2. Hose reel hose not provided.
3. Automatic fire detection & alarming system not provided.
4. The MOEFA system is not provided.
5. The Internal Hydrant not provided.
6. Terrace level Fire fighting Pump capacity of 450 LPM not provided.
7. Overhead tank capacity 20,000 ltrs not provided
8. Exit signage not provided.
9. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR/DFS


Copy to: -

1. M/s Secular House Canteen (A Unit of Masala Bites Secular House Canteen situated at 9/1 Ground Floor, Qutab Institutional Area New Delhi-110067