

4/17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/BP/2022/ W2/BNQT/24

Dated: 2/02.2022

To,


Sh. Shubham Aggarwal,  
M/s Dream Palace,  
A Unit of JMD Enterprises,  
Plot No. 7259, Prem Nagar,  
Shakti Nagar, Delhi-110007

Sub: - Issuance of Fire Safety Certificate in respect of M/s. Dream Palace, A Unit of JMD Enterprises located at No. 7259, Prem Nagar, Shakti Nagar, Delhi-110007

Sir,

In reference to your application No. 2022010700419 dated 07.01.2022 and email dated 18.01.2022 on the subject cited above, it is informed that the case was considered from fire safety point of view and observed that floor plans which are uploaded on MHA portal are in PDF format and are not to scale. Such plans cannot be scrutinized from fire and safety point of view. As this is a new case, therefore you are advised to forward complete set of building plans including section/elevation/lay out plan of current occupancy in the scales as mentioned in UBBL-2016 duly marked with fire and life safety systems as per NBC part-IV to assess the fire and life safety requirement for issuance of fire safety guidelines/ directives.

Yours faithfully,

  
(Virendra Singh)

Dy. Chief Fire Officer  
011-23412225

Copy to:-

1. The Deputy Health Officer,  
North Delhi Municipal Corporation,  
Keshav Puram Zone, New Delhi.

