

240

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/School/WZ/2022/ 77

Dated: 23/02/2022

To,  
The Principal,  
Govt. Sarvodaya Kanya Vidyalaya No. 1,  
Keshavpuram, Delhi-110035.

**Sub. :- Issuance of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya No. 1**  
**(School ID- 1411028) Located at Keshavpuram, Delhi-110035.**


Sir,

This has reference to your letter no. SKVNo. 1/9833 dated 02.02.2022 on the subject cited above. In this connection it is to inform you that the above said School building was re-inspected by the officer concerned of this department on 05.02.2022 in the presence of Sh. Manmohan singh (Lab. Assistant) to check the compliance of shortcomings issued by this departments vide letter no. F6/DFS/MS/School/2015/69 dated 08.01.2015 & letter no. F6/DFS/MS/School/2018/3130 dated 24.07.2018. During inspection, the following shortcomings have been observed:-

1. Widening work of Staircases is in progress.
2. Hose Reels Hose is nonfunctional.
3. Terrace Pump 450 lpms capacity is nonfunctional.

You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Anil Garg)  
Director

Copy to:-

1. The Director, Directorate of Education, Old Secretariat Delhi – 110054.

9- 2/2  
21/2