## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/SZ/2022/ 497

Dated: 23/02/2022

To.

The Building Manager, Hemkunt Hose, 06, Rajendra Place, New Delhi-110008.

Subject: -Regarding renewal of Fire Safety Certificate in r/o Hemkunt House located at 06, Rajendra Place, New Delhi- 08.

Sir.

This is in reference to your Online email dated 31.01.2022 from <a href="hemkuntassociation@gmail.com">hemkuntassociation@gmail.com</a>, on the subject cited above. In this connection it is to inform you that the above said premises have been inspected by the officers concerned of this department on 15.02.2022 in presence of Sh. Baldev Dhiman, Building Manager to check the functionability of fire fighting systems already installed in the building.

During the course of inspection it has been observed that the said building is comprised of basement, ground plus thirteen upper floors. Fire safety arrangement such as Portable fire extinguishers, First aid hose reels, automatic sprinklers system in basement, Internal hydrants, Fire pumps, captive water storage tank for fire fighting, DG set etc. were found provided and followings shortcomings were observed:

- 1. Smoke check doors found removed in entire lobby at some floors/level.
- 2. Smoke/Heat detectors are found not functional at some floors level.
- 3. Electrical shaft found not sealed at some floors level.
- 4. Door closers found removed at some floors level.
- 5. AC compressor found installed in alternate staircase.
- 6. Exit signages, lift signages and floor marking found removed.

In view of the above shortcomings, 'Fire Safety Certificate cannot be renewed at this stage. You are hereby directed to rectify the above shortcomings within a period of thirty days under intimation to this department for taking further necessary action in this matter, otherwise action will be initiated against the said building premises as per Delhi Fire Service Act 2007, Rules 2010.

Copy to:-

1. The Executive Engineer (Building), North MCD, Karol Bagh, Anand Parbat, New Delhi.

2. The Dy. Director (Building), S.D.M.C, Civic Centre, JLN Marg, New Delhi.