

S

C-9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

N F6/DFS/MS/School/2022/SZ/ 78

Dated: 23/02/2022

The Manager,  
Sainik Model School, Plot No.-1/A-Block Extn.  
Vikas Nagar, New Delhi-110059.

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Sainik Model School, Plot No.-1/A-Block Extn., Vikas Nagar, New Delhi-110059.

Sir,

Please refer to your letter no. SMS/01/2021-22 dated 24/01/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 02/02/2022 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Shekhar Jha (Manager) was present and it was observed that the school building is comprised of ground plus three upper floors (3<sup>rd</sup> floor open hall) and have following shortcomings.

1. Second staircase of 1.25 m width is provided instead of 1.5 m.
2. First aid hose reels not provided.
3. Fire pump having 450 lpm output not provided at terrace level.
4. Overhead tank capacity of 10,000 ltrs not provided.
5. Exits signage's are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Anil Garg)

Director

Delhi Fire Service

Copy to:-

1. The Manager, Sainik Model School, Plot No.-1/A-Block Extn., Vikas Nagar, New Delhi-110059.
2. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054. (With a request to take further action as school does not have fire NOC)