

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/ 428

Dated: 23/02/2022

To,

Ms. Ruby Rajeev (Admin Manager) <adminvti@ywcaofdelhi.org>  
YWCA of Delhi Buliding,  
Sector- 10, Dwarka,  
New Delhi - 110075.

Subject: Renewal of Fire Safety Certificate in r/o YWCA of Delhi Hostel Buliding located at  
Sector 10, Dwarka New Delhi - 110075.

Sir,

Please refer to your Email Dated 21/01/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 11/02/2022 in presence of Ms. Ruby Rajeev (Admin Manager).


During the course of inspection flowing shortcomings are observed.

1. Sealing of electrical shaft found removed at some places.
2. Exit signages found removed at some places.
3. Terrace pumps is not on auto mode.
4. Lift Signages found removed at some places.
5. Communication system found removed in the lift cars.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

  
(Anil Garg)  
Director

Delhi Fire Service

Copy to:- Directorate of Education Old Secretariat Delhi - 110054.