

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/Hospital/2022

465

Dated: -25.02.2022

To

The Assistant Engineer (E) HC-1,
Health Maint. Elect. Division (C),
PWD, Lok Nayak Hospital, New Delhi.

Sub:- Regarding issuance of FSC in r/o EDP cell (D-Block) , G.B. Pant Hospital, New Delhi (GIPMER).

Sir,

As per the direction received from higher authority the site was inspected by ADO (CC) & DO (CD) of this department on 21.02.022 in the presence of Mr. Manish JE (E), Mr. Jaiswal & Sh. Pradeep (AE) and the following shortcomings are still not complied :-

1. Fire check door provided in the basement is not properly fixed and the large opening above the fire check door has not been sealed.
2. Temporary structures are erected at upper floors, which create obstruction in means of egress.
3. Smoke management system in basement is not integrated with fire alarm system.
4. Plastic sheet is used in basement for making a store room, required to be removed.
5. Pressurization in lift lobby found nonfunctional

In view of above shortcomings, request for renewal of fire NOC/FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
01123414000

Copy to:-

1. Directorate General of Health Services F-17, Karkardooma , Delhi
2. The Medical Superintendent, G.B. Pant Hospital, New Delhi.
3. The Superintendent Engineer (SE) , Electrical, Health & Maintenance , MSO Building Second Floor , I.P. Estate , New Delhi.
4. The Executive Engineer (E)HMED(C) , PWD, LN Hospital , New Delhi