

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/2022/ (nos) 484

Dated: 25/02/2022

To

The Assistant Engineer (E)-II,
PWD, HMED (Central), Lok Nayak Hospital,
New Delhi - 02.

Sub: Regarding issuance of FSC in r/o MRD, OPD/Surgical /causality block, LNJP Hospital, New Delhi.

Sir,

This has reference to your e-mail < ceepwdhnedc@gmail.com dated 15/02/2022 on the subject cited above. In this regard, it is to inform you that inspection of following blocks of LNJP hospital, New Delhi, was carried out from fire safety point of view by the ADO (CC) & DO (CD) on dated 22.02.22 in presence of PWD official and following shortcomings were observed.

A. Causality , OPD and surgical block

1. Causality block is under renovation.
2. Fire check door found broken /damaged in OPD & Surgical block at some places.
3. Electrical shafts/openings are not sealed horizontally & vertically.
4. One staircase found blocked /locked.
5. Smoke management found non-functional in the basement and not integrated with alarm system.
6. Good house shall be ensured in all blocks.

B. MRD Block

1. Ramp provided in basement found locked and also blocked by storing the items on way to exit.
2. Corridor found blocked /encroached by storing the items.
3. Fire check doors found broken and not closing properly. At some doors, door closers and panic bar found missing.
4. Electric shaft /openings are not sealed horizontally / vertically.
5. Smoke management found non-functional in the basement.
6. Overhead tank of capacity 10, 000 liters provided against the requirements of 20,000 liters capacity.
7. Good housekeeping is not followed in entire area.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Superintendent Engineer (SE), Electrical health & Maintenance , MSO building, Second floor , IP Estate ,ITO , New Delhi
2. The Medical Superintendent, LNJP, Hospital, J. N. Marg, New Delhi - 02.