

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

Dated: 23/02/2022

No.F.6/DFS/MS/2022/ 418

To,

Sh. R.L Bhagat,
Secretary,
Rajindra Bhawan Trust,
210, DDU Marg, New Delhi.

Sub:-Regarding issuance of FSC in r/o Rajindra Bhawan trust at 210, DDU Marg, New Delhi.

Sir,

This has a reference to your letter no. Nil Dated 28/01/22 on the subject cited above. In this connection it is to inform you that the site was inspected by officers concerned of this department on 15/12/2021 in the presence of Dr. Santsaran and observed that the shortcomings issued earlier vide letter no. F6/DFS/MS/2021/CD/Auditorium/2782 dated 29.12.2021 are still not complied.

In view of above, the request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

Encl: As Above,


(Atul Gang)
DIRECTOR
01123414000

Copy to

The Commissioner, North MCD, Civic Centre, New Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F.6/DFS/MS/2021/CD(Auditorium) / 2782

Dated:- 29/12/2021

To,

Sh. R.L Bhagat,
Secretary,
Rajindra Bhawan Trust,
210 DDU Marg, New Delhi.

Sub:-Regarding issuance of FSC in r/o Rajendra Bhawan trust at 210, DDU Marg, New Delhi.

Sir,

This has a reference to your letter no. Nil Dated 17/11/21 on the subject cited above. In this connection it is to inform you that the site was inspected by officers concerned of this department on 21/12/2021 in the presence of Sh. Ashwani and following shortcomings were observed: -

1. Firefighting systems such as hose reel, hydrant, detectors, pumps found nonfunctional.
2. Smoke management system found nonfunctional.
3. MOEFA & PA system found nonfunctional.
4. Over head tank found empty.

In view of above shortcomings, request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR

01123414000

Copy to

The Commissioner, North MCD, Civic Centre, New Delhi.