

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001.

No.F6/DFS/MS/NDZ/2022/ 457

Dated:-25/02/2022

To,

Sh. N. K.Gaur,
Fire Officer,
NDMC, Palika Kendra, New Delhi.

Sub: Regarding renewal of FSC in r/o Shaheed Bhagat Singh Place, Gole Market, New Delhi.


Sir,

This has reference to your email <fo@ndmc.gov.in> dated 10.02.2022 on the subject cited above, it is to inform you that the site was inspected by the officer concerned department on 17/02/2022 in the presence of Sh. V.K. Sharma, LFM (NDMC) and the following shortcomings were observed: -

1. 02 staircases serving to basement & upper floors found locked at basement, second and third floor.
2. Corridor found encroached at second and third floor by erecting a temporary offices.
3. Hose reel & hydrant not covering entire floor area at upper floors.
4. Terrace pump not provided with auto start provision.

In view of above shortcomings, request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit

Yours faithfully


23/2/22

(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

The Chief Architect, NDMC Palika Kendra, New Delhi.