

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/NDZ/2022/ 83

Dated: 24/02/2022

To

The Principal,
M.C.D. Co-ed Primary School,
Gali Bansi Koyale Wali, Ajmeri Gate, Delhi-06

Sub: - Regarding issuance of "Fire Safety Certificate" in r/o M.C.D. Co-ed Primary School, Gali Bansi Koyale Wali, Ajmeri Gate, Delhi-06

Madam,

With reference to letter no. nil dated 07.02.2022 on the subject cited above. It is to inform you that the school building has been inspected by Assistant Divisional Officer (SPM) from this department on 17.02.2022 in the presence of Miss. Kanta (Incharge) and it was observed that the shortcomings already communicated by this department vide letter no. F6/DFS/MS/2018/ School/1154 dated 21.03.2018 (Photocopy enclosed) have not been rectified till date. The School management is requested to rectify the shortcomings at the earliest.

In view of above, Fire Safety Certificate cannot be considered at this stage.


Yours faithfully,



(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025



Copy to:-

The Director of Education,
North Delhi Municipal Corporation, City S.P. Zone, Old Hindu College, Kashmiri Gate, Delhi

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/NDZ/2021/ 81

Dated: 17/02/2021

To

The Principal,
M.C.D. Co-ed Primary School,
Gali Bansi Koyale Wali, Ajmeri Gate, Delhi-06

Sub: - Regarding issuance of "Fire Safety Certificate" in r/o M.C.D. Co-ed Primary School, Gali Bansi Koyale Wali, Ajmeri Gate, Delhi-06

Madam,

With reference to letter no. nil dated 29.01.2021 on the subject cited above. It is informed that the school building has been inspected by Assistant Divisional Officer (SPM) from this department on 11.02.2021 in the presence of Mr. Kamesh Kumar (office attendant) and it was observed that the shortcomings already communicated by this department vide letter no. F6/DFS/MS/2018/ School/1154 dated 21.03.2018 (Photocopy enclosed) have not been rectified till date. The School management is requested to rectify the shortcomings at the earliest.

In view of above, Fire Safety Certificate cannot be considered at this stage.


Yours faithfully,



(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025



Copy to:-

The Director of Education,
North Delhi Municipal Corporation, City S.P. Zone, Old Hindu College, Kashmiri Gate, Delhi

97

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No.F6/DFS/MS/2018/School/1154

Dated

21/3/18

To

The Principal,
MCP Co-ed, Primary School
Gali Bansi Koyale Wali, Ajmeri gate, Delhi-06.

Sub: Regarding issuance of FSC in r/o MCP Co-ed, Primary School Gali Bansi Koyale Wali, Ajmeri gate, Delhi.-110006.

Sir,


Please refer to your letter No. -Nil- dated 15/02/2018 on the subject noted above. In this regard, it is to inform you that school premises has been inspected by the officer concerned of this department in the presence of Principal of school on 12/03/18.

During inspection, following shortcoming was observed.

1. Road width is less than required width 6 mtr. Hence building is not accessible to fire engines
2. Width of staircase is 1.0 mtr. which is less than required width i.e. 1.50 mtr.& alternate staircase of not less then 75 cm may be provided.

Hence Fire Safety Certificate can not be considered at this stage.

Yours faithfully,


(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

The Director of Education,
Old Secretariat, Delhi-110054.

92

19/3