

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

E112

No. F.6/DFS/MS/NDZ/2022/HTL/04

Dated: 02.02.2022

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- 2021112627321 in r/o Red Fox Hotel located at Plot No. 6, Community Centre, Sec-A, Kondli, Delhi – 110096.

Sir,

This has a reference to online application ID No.- **2021112627321** dated 16/12/2021 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 15.02.2022 in the presence of Mr. Ganesh Bhadari. During inspection following shortcomings was observed:-

1. 6 meter access around the building not provided (Encroached).
2. Few of the Electrical shaft not sealed properly.
3. Smoke management system not integrated.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

9CAB

Copy to:-

1. The Manager, Red Fox Hotel, Plot No. 6, Community Centre, Sec-A, Kondli, Delhi –110096.