

e-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/ 208

Dated 28/02/2022

To

The Dy. Health Officer, (South Zone)  
Public Health Department,  
SDMC, Aurobindo Marg,  
Green Park, Delhi 110016

**Sub: -** Regarding issuance of fire safety certificate in r/o M/s Tata Starbucks Pvt Ltd. (A Unit of Starbucks Coffee A Tata Alliance) located at G-04 & 05 Sangam Mall, R. K Puram, New Delhi 110048.

Sir,

This has reference to your MHA Portal ID No. 2022010400199 dated 04/01/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 11.02.2022 in the presence of Mr. Shahi'd to ascertain the availability and operability of the protection and fire safety measures as installed in the building. During the course of inspection, the following shortcomings/ observation were noticed.

1. There is one exit door having width of 1.00 mtr. The minimum widths of two exits required 1.50 mtr each as per UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR / DFS

Copy to:

1. The Authorized Signature, M/s Tata Starbucks Pvt Ltd. (A Unit of Starbucks Coffee A Tata Alliance) located at G-04 & 05 Sangam Mall, R. K Puram, New Delhi 110048